

Office of the  
**Taldaha Majdia Gram Panchayat**  
Vill.+P.O. Majdia , Block- Krishnaganj Dist. Nadia

Ref. No. 226/TMG/P/22

Date: 11/5/2022

**SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

It is certified that an inspection team headed by **Mr. Sujit Ghosh , Executive Assistant**, Talhada Majdia Gram Panchayat (Name of the Officer with Designation) from **Taldaha Majdia Gram Panchayat** ( Name of the Department /Offffice ) inspected the **NBM MODEL SCHOOL**, Vill+P.O. Majdia ,P.S. Krishnaganj, Dist. Nadia, W.B. Pin-741507 on 06/05/2022 and found that the **NBM MODEL SCHOOL** (Name of School ) has safe drinking water facilities for the students and member of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central / State/ U.T. Govt. The above valid for the period of 5 years.




11.05.2022  
Executive Assn. cum  
Taldaha Majdia Gram Panchayat  
Nadia, Nadia


Signature with seal

Name of the Officer: SUJIT GHOSH

Designation E.A

To  
The Principal  
NBM MODEL SCHOOL  
Vill.+P.o. Majdia, Dist. Nadia  
West Bengal, Pin-741507

  
Manager  
NBM MODEL SCHOOL  
Vill+P.O.-Majdia, Dist.-Nadia  
Pin-741507

  
Principal  
NBM MODEL SCHOOL  
Vill+PO -Majdia, Dist.-Nadia  
Pin-741507

GOVERNMENT OF WEST BENGAL  
PUBLIC HEALTH ENGINEERING DIRECTORATE  
KRISHNAGAR SUB - DISTRICT LABORATORY UNDER KRISHNAGAR SUB - DIVISION  
WATER QUALITY TEST REPORT

Memo No : 1076/RSD  
Ref Memo No :

Date : 10/11/22  
Date :

PARAMETER	DESIRABLE LIMIT	PERMISSIBLE LIMIT
pH	6.5 to 8.5	NO
TOTAL HARDNESS	200 mg/lit	RELEXATION
IRON	0.3 mg/lit	1.0 mg/lit
ARSENIC	0.01 mg/lit	0.01 mg/lit
TC		0/100 ml
FC		0/100 ml

SL NO	SOURCE DETAILS	TYPE OF SOURCE	DATE OF COLLECTION	DATE OF TESTING	pH	TOTAL HARDNESS (mg/l)	IRON (mg/l)	As (mg/l)	TC	FC
1	NBM MODEL SCHOOL MAJIDIA, NADIA	PUMP	09-11-2022	09-11-2022	7.33	220	2.17	0.01	0	0

SAMPLE COLLECTED BY : FACILITATOR

WATER ANALYST  
KRISHNAGAR SUB-DISTRICT LAB  
KRISHNAGAR SUB-DIVISION, P.H.E. D/O.



Manager  
NBM MODEL SCHOOL  
Vill+P.O.-Majdia, Dist.-Nadia  
Pin-741507

ASSISTANT ENGINEER  
KRISHNAGAR SUB - DIVISION  
P.H. ENGINEERING D/O  
Assistant Engineer  
Krishnagar Sub-Division  
P.H.E. D/O.

Principal  
NBM MODEL SCHOOL  
Vill+P.O.-Majdia, Dist.-Nadia  
Pin-741507