



Government Of West Bengal
Office Of The Divisional Fire Officer, Nadia
West Bengal Fire & Emergency Services
Azad Hind Sarak, P.O.- Ghurni, P.S.- Kotwali, Pin :- 741103

Memo no.:IND/WB/FES/20192020/85641

Date: 13-11-2020

From:

Divisional Fire Officer, Nadia

West Bengal Fire & Emergency Services

To: NBM Model School

Mouja- Majdia, JL No- 59, Khatian No- 2684, 2685, Plot No- 407, 2943, Under Taldaha - Majdia, Nadia - 741507.

Sub: Fire Safety Certificate for existing construction of G+I Storied educational building under group of institutional building in the name & style "NBM Model school" at Premises No. Mouza-Majdia, JL No. 59, LR Plot No. 407, 2943, LR Khatian No. 2684 2685, Vill & P.O:- Majdia, P.S:-Krishnaganj, Under Taldaha-Majdia G.P., Dist:- Nadia, West Bengal.

This is in reference to your application no. 0125189201000115 dated 22-10-2020 regarding the Fire Safety Certificate for existing construction of G+I Storied educational building under group of institutional building in the name & style "NBM Model school" at Premises No. Mouza-Majdia, JL No. 59, LR Plot No. 407, 2943, LR Khatian No. 2684 2685, Vill & P.O:- Majdia, P.S:-Krishnaganj, Under Taldaha-Majdia G.P., Dist:- Nadia, West Bengal.

The performance of the Fire Fighting System as incorporated in the buildings were tested at random and found satisfactorily working condition. In view of the above this office is releasing the Fire Safety Certificate for occupancy of the aforesaid building.

Recommendation:

- 1.All the Fire Safety Recommendations/Revised Fire Safety Recommendations which were issued vide this Office Memo No. IND/WB/FES/20192020/85641, Dated:- 28/02/2020 be followed strictly at all time.
- 2.Driveway must have to be kept free of obstruction at all time for EASY movement of fire Appliances. No parking will be allowed on the driveway.
3. The interior finish decoration of building shall be made with low flame spread materiel confirming I.S. specification.
4. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the Building shall be strictly maintained.

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125189201000115.

Page : 1

Manager

NBM MODEL SCHOOL
Vill+P.O.-Majdia, Dist.-Nadia
Pin-741507

Principal

NBM MODEL SCHOOL
Vill+P.O.-Majdia, Dist.-Nadia
Pin-741507


Powered By **emSigner** For secure paperless solutions
Please visit www.emsigner.com

5. Existing Electrical wiring of the whole building shall have to be carefully checked for any damage in and tear in them, particularly lines above false ceiling & ducts.
6. A fire control room including a close circuit T.V./ Monitor system will have to be installed which will observe all the floor of the Building.
7. The notice of Fire Fighting equipments and Evacuation plan shall be maintained and displayed at all venerable places of the Building.
8. The Employees and security staff shall be well conversant with installed Fire Fighting Equipments of the building and to operate in the event of Fire and Testing.
9. Mock Fire practice evacuation drill shall to be performed periodically with participant of all the occupants of the building.
10. Main and meter room shall be protected with Co2 or DCP Fire Extinguishers confirming I.S. Specifications.
11. First-Aid Fire Fighting system shall be provided as per I.S. Specification.
12. Arrangement shall have to be made for regular checking, testing and maintenance, of all the Fire Fighting installation of the Building to keep them in perfectly good working Condition at all the time.
13. If required the old line shall have to be replaced with new lines the cables shall always be laid in M.S. conduit pipes continuously bonded to the earth.
14. Periodical Flashing of water in hydrants pipe line shall be made to maintain the efficient working performance of above mentioned system.
15. Fire Safety audit to be conducted at regular interval and to be recorded in the fire prevention maintenance register.
16. Transformer & switch Gear room (if applicable) shall be protected with CO2 or D.C.P. Fire Extinguisher conforming I.S. Specification.
17. Storage of volatile flammable liquid shall be prohibited and the handling of such liquids shall restricted to science

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the 'Verification of Digitally Signed Document' link and keying in the Unique Number : 0125189201000115.

Page : 2


Manager
NBM MODEL SCHOOL
Vill+P.O.-Majdia, Dist.-Nadia
Pin-741507


Principal
NBM MODEL SCHOOL
Vill+P.O.-Majdia, Dist.-Nadia
Pin-741507

Powered By  For secure paperless solutions
Please visit www.emsigner.com

Laboratory only.

18. If gas use in the laboratory shall be provided with an approve out side gas shut-off valve conspicuously marked.

19. Chemicals used in laboratory must be kept in separated isolated stores in proper sealed containers. Lab Asst. Must be alert for its maintenance during closing by lock & key after class hours for any spillage, Fumes, Loosen caps, corrosiveness, acids, main valves for Bunsen Burners etc.

20. Fire Licence shall have to be obtained from the licence section of the department for proposed storing of highly combustible articles and procession with L.P.G., which come under purview of licence section as per Fire service Act-1950 (with up to date amendment).

21. This Fire Safety Certificate is valid for Three years and have to be renewed every three years interval from the date of Issue of this letter. In every three years Certificate is to be obtained from the Director General, West Bengal Fire & Emergency Services, regarding the Performance of all the life & Fire Safety arrangements and installation of the Building.


22. Any deviation or changes the building in respect of the approved plan drawing, without prior permission from this office, this fire safety certificate will be treated cancelled automatically.

Signature valid

Digitally signed by RATAN
KUMAR HANDEK
Date: 2020.11.13 17:55:57 IST

Divisional Fire Officer, Nadia
West Bengal Fire & Emergency Services


Manager
NBM MODEL SCHOOL
Vill+P.O.-Majdia, Dist.-Nadia
Pin-741507


Principal
NBM MODEL SCHOOL
Vill+P.O.-Majdia, Dist.-Nadia
Pin-741507