



सत्यमेव जयते

Government of West Bengal  
Office of the Divisional Fire Officer  
West Bengal Fire & Emergency Services  
Azad Hind Sarak, P.O.:- Ghurni, P.S.:- Kotwali, Pin :- 741103

Memo No.: FSR/IND/WB/FES/20192020/85641

Date : 18-07-2024

From :  
Divisional Fire Officer  
Nadia Division,  
West Bengal Fire & Emergency Services

To :  
NBM Model School  
Mouja- Majdia, JL No- 59, Khatian No- 2684, 2685, Plot No- 407, 2943, Under Taldaha - Majdia, Nadia - 741507

Sub : Renewal of Fire Safety Certificate for the existing construction of G+1 storied building under group Educational in favour of NBM MODEL SCHOOL, at the premises: Mouja- Majdia, JL No- 59, Khatian No- 2684, 2685, Plot No- 407, 2943, Under Taldaha - Majdia, Dist.Nadia PIN- 741507.

This is in reference to your AIN 211912406300001247 dated 05-Jul-2024 regarding Renewal of Fire Safety Certificate for the existing construction of G+1 storied building under group Educational in favour of NBM MODEL SCHOOL, at the premises: Mouja- Majdia, JL No- 59, Khatian No- 2684, 2685, Plot No- 407, 2943, Under Taldaha - Majdia, Dist.Nadia PIN- 741507..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

**Recommendation:**

1. Driveway must be free of any type of obstruction for easy movement of fire appliances. No parking will be allowed on the drive way.
2. To eliminate risk of fire hazard, good housekeeping both for inside and outside of the building shall be



*[Handwritten Signature]*

Manager  
NBM MODEL SCHOOL  
P.O.- Majdia, Dist.- Nadia

*[Handwritten Signature]*  
Principal  
NBM MODEL SCHOOL  
P.O.- Majdia, Dist.- Nadia  
Aff. No.- 2430394, School Code-16224

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912406300001247

strictly maintained.

3. Existing electrical wiring of the whole building shall have to be carefully checked for any were and tear in them, particularly lines above false ceiling and ducts.
4. A fire control room including a closed circuit TV system will have to be maintained which observe all floor of the building.
5. The notice of fire fighting and evacuation plan from the building shall be prepared and displayed at all suitable places of the building.
6. The employees and security staff shall be conversant with installed Fire Fighting equipments of the building and to operate in the event of Fire and Testing.
7. Mock Fire practice and evacuation drill shall be performed periodically with all Teaching, Non-Teaching, Security staffs and students of the occupancy.
8. Transformer and switch gear room shall be protected with automatic co2 or DCP fire extinguisher conforming I.S specification.
9. A crew of trained Fireman under the experienced officer shall be maintained round the clock for safety of the building.
10. Arrangement shall be made for regular checking, testing and proper maintenance of all the Fire Safety installation and equipment's installed in the building to keep them in perfectly good working conditions at all times.
11. Periodical flushing of water in the hydrant pipe line shall be made to maintain the efficiency working performance of above mentioned system.
12. The fire and electrical safety audit to be conducted a regular interval and to be recorded in the fire prevention maintenance register.
13. Fire Notice for Fire Fighting and evacuation from the building shall be prepared and be displayed at all vulnerable places of the building.
14. Directional sign of escape route shall be displayed prominently.
15. Fire License should be obtained for hazardous materials.
16. Fire Suppression System and Emergency Lighting always attached to Emergency Backup.

This Fire Safety certificate is valid for three years, subject to maintained above recommendations and has to be renewed every three years from the date of issue of this letter.

Any deviation and changes the nature of the use of the building in respect of submitted plan drawing, without obtaining prior permission from the office, the RFSC shall be treated cancelled.


Memo No.:

Valid Upto : 17-Jul-2027

FSR/IND/WB/FES/20192020/85641



Manager  
NBM MODEL SCHOOL  
P.O.- Majdia, Dist.- Nadia  
Aff. No.- 2430394, School Code-16224



Principal  
NBM MODEL SCHOOL  
P.O.- Majdia, Dist.- Nadia  
Aff. No.- 2430394, School Code-16224

Signature Not Verified

Digitally Signed.  
Name: SUBRATA GUHA  
Date: 18-Jul-2024 11:52:18  
Reason: D-Sign  
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: [edistrict.wb.gov.in](http://edistrict.wb.gov.in) and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912406300001247