



Government of West Bengal
Office of the Block Medical Officer of Health
Krishnaganj Block, Nadia
Krishnaganj Rural Hospital, Nadia, 741506
email: krishnaganjbphc.nadia@gmail.com/bpmukris@gmail.com

No.: BMOH/KNJ/967


Dated: 24/09/2026

To Whom It May Concern

This is to certify that the drinking water sample collected from NBM Model School, Vill. & P.O. Majdia, District – Nadia, West Bengal, was tested by the Nadia District Water Testing Laboratory, PHED, vide Memo No. 1609/KSD dated 03.06.2026.

As per the findings of the said laboratory test report, the quality of the drinking water sample is satisfactory and suitable for drinking purposes. It was also found that the school maintains the hygienic sanitization condition in the school building including toilets and campus.

This certificate is issued to NBM Model School on the basis of the aforesaid laboratory test report for official purposes.



24.09.26
Block Medical Officer of Health
Krishnaganj Block, Nadia
Block Medical Officer of Health
Krishnaganj Block, Nadia

[Signature]
Manager
NBM MODEL SCHOOL
P.O.- Majdia, Dist.- Nadia
Aff. No.- 2430394, School Code-16224

[Signature]
Principal
NBM MODEL SCHOOL
P.O.- Majdia, Dist.- Nadia
Aff. No.- 2430394, School Code-16224

GOVERNMENT OF WEST BENGAL
PUBLIC HEALTH ENGINEERING DIRECTORATE
NADIA DISTRICT WATER TESTING LABORATORY
WATER QUALITY TEST REPORT

MEMO NO : 1609/KSD
REF MEMO NO :

DATE :
DATE :

3/6/26-

PARAMETER	DESIRABLE LIMIT	PERMISSIBLE LIMIT
pH	6.5 to 8.5	NO RELAXATION
TURBIDITY	1 NTU	5 NTU
TDS	500 mg/l	2000 mg/l
IRON	0.3 mg/lit	NO RELAXATION
ARSENIC	0.01 mg/lit	0.01 mg/lit
TC		0/100 ml
FC		0/100 ml

MEMO NO : 24/NBMMS/2026 Dt.01.06.2026

SL NO	SOURCE DETAILS	DATE OF SUBMISSION	DATE OF TESTING	pH	TDS (mg/l)	TUR (NTU)	IRON (mg/l)	As (mg/l)	TC	FC
1	NBM MODEL SCHOOL	01.06.2026	03.06.2026	6.31	46.4	0.77	0.34	0.01	2	0

SAMPLE COLLECTED BY : CONCERNED PERSON
NON ACIDIFIED SAMPLE RECEIVED

[Signature]
Manager
NBM MODEL SCHOOL
P.O.- Majdia, Dist.- Nadia
Aff. No.- 2430394, School Code-16224

[Signature]
Principal
NBM MODEL SCHOOL
P.O.- Majdia, Dist.- Nadia
Aff. No.- 2430394, School Code-16224

[Signature]
WATER ANALYST

NADIA DISTRICT WATER TESTING LAB
KRISHNAGAR SUB-DIVISION, P.H.E. Div.

[Signature]
JUNIOR ENGINEER
KRISHNAGAR SUB-DIVISION
P.H. ENGINEERING DTE.

[Signature]
ASSISTANT ENGINEER
KRISHNAGAR SUB-DIVISION
P.H. ENGINEERING DTE.